Installation Instructions

UPS BRACKET, CUBE-IT

WARNING: Improper use of this product or failure to follow these instructions may result in equipment damage, peronal injury, or death. Read and understand all instructions for proper installation and use of this product.

Intended Use

Compatible with LS350A and LS600A UPS, or equivalent.

Assembly Sequence

1. Position UPS on Bracket at desired location. Attach to Bracket using M3 Hardware, 4X. Fig 1.
2. Attach Bracket to upper or lower screw bosses on Rear Chassis using 10-24 hardware, 4X. Fig 2.

Required Tools

Manual or Powered Philips Driver
5/16" Socket/Wrench

Included Hardware

QTY	DESCRIPTION
4	10-24 Bolt
4	Star Washer
4	M3 Screw





Fig 1.






Fig 2.

CHATSWORTH PRODUCTS

IIS-740977-001, 02/26/24, Rev. 1, CPI/SJG
800-834-4969 (USA & Canada) • www.chatsworth.com • techsupport@chatsworth.com
For international phone numbers, see our website or contact CPI Tech Support.

This drawing contains proprietary and confidential information and is protected by U.S. and international law. Unauthorized reproduction, disclosure or use of the drawing or the information therein is expressly forbidden except as agreed to in writing by Chatsworth Products, Inc.